

Article 5: Fire Protection and Prevention

Division 9: Fire Department Access and Water Supply

(“Fire Department Access and Water Supply”

added 1-8-1996 by O-18242 N.S.)

§55.0901 Fire Department Access and Water Supply

901.1 Scope through 901.4.2 Fire apparatus access roads. Sections 901.1 through 901.4.2 of the C.F.C. (1998 Edition) have been adopted without change pursuant to section 55.0101(a).

901.4.3 Fire Protection equipment and fire hydrants. Fire protection equipment and fire hydrants shall be clearly identified in a manner approved by the Fire Chief to prevent obstruction by parking and other obstructions. When required by the Fire Chief, hydrant locations shall be identified by the installation of reflective blue-colored markers. Such markers shall be affixed to the roadway surface, approximately centered between curbs, and at a right angle to the hydrant.

901.4.4 Premises identification through 901.6 Fire Protection in Recreational Vehicle, Mobile Home and Manufactured Housing Parks, Sales Lots and Storage Lots. Sections 901.4.4 through 901.6 of the C.F.C. (1998 Edition) have been adopted without change pursuant to section 55.0101(a).

(Retitled to “Fire Department Access and Water Supply” and amended 7-19-1999 by O-18659 N.S.)

§55.0902 Fire Department Access

902.1 General through 902.2.2 Specifications. Sections 902.1 through 902.2.2 of the C.F.C. (1998 Edition) have been adopted without change pursuant to section 55.0101(a).

902.2.2.1 Required access. - no change.

902.2.2.2 Surface through 902.4 Key boxes. Sections 902.2.2.2 through 902.4 of the C.F.C. (1998 Edition) have been adopted without change pursuant to section 55.0101(a).

(Amended 7-19-1999 by O-18659 N.S.)

§55.0903 Water Supplies and Fire Hydrants

903.1 General. Section 903.1 of the C.F.C. (1998 Edition) has been adopted without change pursuant to section 55.0101(a).

903.2 Required Water Supply for Fire Protection. An approved water supply capable of supplying the required fire flow for fire protection shall be provided to all premises upon which facilities, buildings or portions of buildings are constructed or moved into or within the jurisdiction after August 18, 1999. When any portion of the facility or building protected is in excess of 300 feet (91440 mm) from a water supply on a public street, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the Fire Chief. See C.F.C. (1998 Edition) section 903.4.

903.3 Type of Water Supply through 903.4.4 Maintenance and use of hydrants. Sections 903.3 through 903.4.4 of the C.F.C. (1998 Edition) have been adopted without change pursuant to section 55.0101(a).
(Amended 7-19-1999 by O-18659 N.S.)